



C O R G O

C O R G O

Date : 10th December 2022

TYPE APPROVAL CERTIFICATE

FOR COMPLIANCE TO MASS EMISSION FOR
DEDICATED NG ENGINE (upto 800 kW)

Cert	Report	Specs	Drg	Total
02	03	07	15	27 pgs



1. In order to establish compliance to the provisions of emission limits, applicable as on date, documentary verification/necessary testing was carried out, on following generator set engine model(s), submitted by the engine manufacturer / supplier referred below:

Portable Generator Set Supplier		Portable Engine Assembler/Importer	
M/s. OGM Impex Private Limited Addr: A-264 2nd Floor Okhla Industrial Area Phase-1 New Delhi		M/s OGM Impex Private Limited Engine imported from M/s.Chongqing Yihu Engine Machinery Co. Ltd., Jiulongpo District Chongqing,China and imported by M/s OGM Impex Private Limited, New Delhi Plant : New Delhi	
Engine Family	Portable Generator Set Manufacturer Plant	Portable Generator Assembler/Importer	
F-2	M/s. Chongqing Yihu Engine Machinery Co. Ltd , Jiulongpo District Chongqing,China	M/s. OGM Impex Private Limited A-264 2nd Floor Okhla Industrial Area Phase-1 New Delhi	
Generator Set Engine Model		Displacement	Class
A 6500 S		420 cm ³	Class 3
Generator Set Model(s)/Brand Name		Type	Date of Compliance of Emission Norms
A 6500 / ALPHA Brand		Petrol Start, Petrol Run	1 st August 2014
		Variant(s)	NA

2. Validity of the Certificate

This Type Approval Certificate is valid till	1	The validity of existing emission norms under Notification No. GSR 535(E) dt. 07.08.2013 or until further amendment in the MoEFCC rule, whichever is earlier.
	2	No change in technical specification of the engine specified
	3	Explicitly the Type Approval Certificate withdrawn by the engine supplier

3. It is certified that the above generator set engine model comply with the emission limits for petrol and kerosene run generator sets (upto 19 kW), as prescribed under the following rules, notified by Ministry of Environment, Forest and Climate Change (MoEFCC), Govt. of India:

Rule No.	Description	Notification	Date
88(A)	Emission limits for new petrol and kerosene generator set engine upto 19 Kw	GSR 535 (E)	07.08.2013

4. COP :

COP will be applicable as per CPCB Procedure, for details refer COP-Annexure

Please turn over for Disclaimer

AUTHORISED SIGNATORY			
VIJAYANTA AHUJA DEPUTY GENERAL MANAGER		SAURABH DALELA DIRECTOR	
		Page 1 of 2	