



C C S G 0522

Date : 26<sup>th</sup> June 2023

C-ICM/S0522 Kota Limi 30-II M/s.

# CERTIFICATE FOR CONFORMITY OF PRODUCTION

Cert	Report	Total
01	05	06 pgs



M/s. Escorts Kubota Limited  
Plant: Faridabad

1. Based on the verification of documents and trials conducted on the engine model(s) "G-30-II" manufactured by M/s Escorts Limited, Faridabad randomly selected from their plant at Faridabad, it is certified that the following diesel genset engine model of family F7 comply with the provisions of Verification of the Conformity of Production (CoP) as per para 7.3 of CPCB procedure (System & Procedure for compliance to emission limits for new diesel engines (upto 800 kW) for genset application) and Rules notified by Ministry of Environment, Forest and Climate Change (MoEFCC) Govt. of India.

Notification No.	Date	Rule No.		
GSR 771 (E)	11.12.2013	Rule 95 of Environment (Protection) Rules, 2013 (Third Amendment)		
GSR 232(E)	31.03.2014	Rule 95 of Environment (Protection) Rules, 2014 (Third Amendment)		
Fuel	Plant	Manufacturer	Engine Power	Cubic Capacity (cm <sup>3</sup> )
Diesel	Faridabad	M/s. Escorts Limited	31.2 kW @ 1500 rpm	2146
Engine Family	F7		Manufacturing Period	COP Year
Parent	G-30-II		01/07/2022 to 30/06/2023	2022 to 2023
Variant (s)	G-40-II (Engine Power : 42.8 kW @ 1500 rpm) G-25-II (Engine Power : 25.5 kW @ 1500 rpm)			

2 This certificate is valid upto June 30th, 2023 (Refer G.S.R. 804(E) dt. 03.11.2022).

Type approval certificate no. for reference	ICAT/MOEF/DGTA/ESCORTS-F7/J-0287 dt. 24.03.2014	
COP Report Reference	CC0ES.0293 Dt. 12.06.2023	
ICAT Case Reference	IOCS No. 166096	Please turn over for DISCLAIMER

### AUTHORISED SIGNATORY

SITARAM KASHYAP DEPUTY GENERAL MANAGER	MADHUSUDAN JOSHI DEPUTY GENERAL MANAGER		Page 1 of 1