

C C R G 0665

G 0665  
CCRG0665G0665

Date : 20<sup>th</sup> June 2022

Cert	Report	Total
01	04	05 pgs

# CERTIFICATE

FOR  
CONFORMITY OF PRODUCTION



M/s. Simpson & Co.Ltd

Plant: Sembium

1. Based on the verification of documents and trials conducted on the engine model(s) "SJ327T(G)-F19" manufactured by M/s. Simpson & Co.Ltd, Huzur Gardens, Sembium, Chennai randomly selected from their plant at Sembium, it is certified that the following diesel genset engine model of family F19 comply with the provisions of Verification of the Conformity of Production (CoP) as per para 7.3 of CPCB procedure (System & Procedure for compliance to emission limits for new diesel engines (upto 800 kW) for genset application) and Rules notified by Ministry of Environment, Forest and Climate Change (MoEFCC), Govt. of India.

Notification No.	Date	Rule No.
GSR 771 (E)	11.12.2013	Rule 95 of Environment (Protection) Rules, 2013 (Third Amendment)
GSR 232(E)	31.03.2014	Rule 95 of Environment (Protection) Rules, 2014 (Third Amendment)

Fuel	Plant	Manufacturer	Engine Power	Cubic Capacity (cm <sup>3</sup> )
Diesel	Sembium	M/s. Simpson & Co.Ltd	28.71 kW @ 1800 rpm	2701
Engine Family	F19		Manufacturing Period	COP Year
Parent	SJ327T(G)-F19		01/07/2021 to 30/06/2022	2021 to 2022
Variant (s)	Nil			

2. Next CoP test shall be carried out before 1st July 2023 (i.e. once in a year) or after production of every 1000 units for the above family, whichever is earlier.

Type approval certificate no. for reference	ARAI/MOEF/DGTA/SCL-F19/2014-08 Dt.18.08.2014		
COP Report Reference	CCOER 0246 Dt.13.06.2022		
ICAT Case Reference	IOCS NO. 15		

AUTHORISED SIGNATORY



Please turn over for DISCLAIMER

PRASHANT VIJAY  
DEPUTY GENERAL MANAGER

PAMELA TIKKU  
DIRECTOR (Offg.)

Page 1 of 1  
1