



C O S G 0594

C O S G 0594

Date : 18th October 2023

TYPE APPROVAL CERTIFICATE

COMPLIANCE TO MASS EMISSION & SMOKE NORMS
FOR GENSET DIESEL ENGINE (upto 800 kW)

Cert	Report	Specs	Drg	Total
02	06	12	09	29 pgs



1. In order to establish compliance to the provisions of mass emission & smoke limits, applicable as on date, documentary verification / necessary testing was carried out, on following engine model(s), submitted by the engine manufacturer/supplier referred below:

This Certificate Supercedes	Engine Manufacturer		
Current Certificate	M/s Baudouin (Weifang) Power Co. Ltd. No. 197A, Fushou East Street, High - Tech Development Zone, Weifang, China Plant : China		
Engine Family	Engine Supplier (Manufacturer / Importer)		Import Category
4M12G	M/s Shandong Heavy Industry India Pvt. Ltd., Survey No. 280/281, Village Mann, Taluka Mulshi, Hinjawadi Phase-II, Pune - 411 057, Maharashtra, India		
Parent Engine		Cubic Capacity (cm ³)	Gross Engine Power
4M12G6D4/5		4580	135 kW @ 1500 rpm
Variant(s)			Compliance of Norms w.e.f
ANNEXURE-I			01.07.2023

2. Validity of the Certificate

This Type Approval Certificate is valid till	1	The validity of existing emission norms under Notification No. GSR 804(E) dt. 03.11.2022 or until further amendment in the MoEFCC rule, whichever is earlier.
	2	No change in technical specification of the engine specified
	3	Explicitly the Type Approval Certificate withdrawn by the engine supplier
	4	Till COP is not missed / Till COP procedure compliance as per CPCB Administrative Procedure is obtained within prescribed time frame.

3. It is certified that the above Diesel engine model(s) comply with the emission limits for Genset Engines powered by CI engines under power category (56<P≤560)kW, as prescribed under the following rules, notified by Ministry of Environment, Forest and Climate Change (MoEFCC), Govt. of India:

Rule No.	Description	Notification	Date
Environment (Protection) Rule, 1986 in the schedule I, Serial number 88	Emission limits for new engines used for power generating set (Genset) application upto 800 kW Gross Mechanical Power	GSR 804 (E)	03.11.2022

4. COP :

COP will be applicable as per CPCB Procedure, for details refer COP-Annexure.

Please turn over for Disclaimer

AUTHORISED SIGNATORY			
SITARAM KASHYAP DEPUTY GENERAL MANAGER			
			Page 1 of 2