



C O S G 0614

C O S G 0614

Date : 10<sup>th</sup> November 2023

# TYPE APPROVAL CERTIFICATE

COMPLIANCE TO MASS EMISSION NORMS FOR  
PETROL RUN PORTABLE GENERATOR SETS

Cert	Report	Specs	Drg	Total
02	03	07	04	16 pgs



1. In order to establish compliance to the provisions of mass emission limits, applicable as on date, documental verification / necessary testing was carried out, on the following Portable generator set engine model(s), submitted by the engine **manufacturer/supplier** referred below:

Portable Generator Set Supplier		Portable Engine Assembler/Importer	
M/s OGM Impex Pvt. Ltd. Addr: A-264 2nd Floor, Okhla Industrial Area, Phase-I, New Delhi-110020		M/s OGM Impex Pvt. Ltd. Engine imported from M/s Chongqing Yihu Engine Machinery Co. Ltd., Hangu Industry Zone, Jiulongpo District Chongqing, China and imported by M/s OGM Impex Pvt. Ltd., New Delhi <b>Plant : New Delhi</b>	
Engine Family	Portable Generator Set Manufacturer Plant	Import Category	
F1	M/s Chongqing Yihu Engine Machinery Co. Ltd, Hangu Industry Zone, Jiulongpo District Chongqing	M/s. OGM Impex Pvt. Ltd. A-264 2nd Floor, Okhla Industrial Area, Phase-I, New Delhi	
Generator Set Engine Model		Displacement (cm <sup>3</sup> )	Class
A3600		223	Class 2
Generator Set Model(s) / Brand Name		Type	Variant(s)
A3600 / ALPHA		Petrol Start, Petrol Run	NIL
		Compliance of Norms w.e.f	01.07.2023

2. Validity of the Certificate



This Type Approval Certificate is valid till	1	The validity of existing emission norms under Notification No. GSR 804(E) dt. 03.11.2022 or until further amendment in the MoEFCC rule, whichever is earlier.
	2	No change in technical specification of the engine specified
	3	Explicitly the Type Approval Certificate withdrawn by the engine supplier
	4	Till COP is not missed / Till COP procedure compliance as per CPCB Administrative Procedure is obtained within prescribed time frame.

3. It is certified that the above mentioned engine model(s) comply with the emission limits for Genset Engines powered by SI engines under Engine Displacement (cc) category (>99 and upto 225), as prescribed under the following rules, notified by **Ministry of Environment, Forest and Climate Change (MoEFCC), Govt. of India:**

Rule No.	Description	Notification	Date
Environment (Protection) Rule, 1986 in the schedule I, Serial number 88	Emission limits for new engines used for power generating set (Genset) application upto 19 kW Gross Mechanical Power	GSR 804 (E)	03.11.2022

4. COP : COP will be applicable as per CPCB Procedure, for details refer COP-Annexure.

Please turn over for Disclaimer

AUTHORISED SIGNATORY			
		 <b>SAURABH DALELA</b> DIRECTOR	
<b>SITARAM KASHYAP</b> DEPUTY GENERAL MANAGER		Page 1 of 2	