



C	O	S	G	0530	E01
---	---	---	---	------	-----

Date : 12th January 2024

COP Annexure-I




Criteria*	COP Required
RECD Manufacturer/Importer/Retrofitter	<p>RECDs fitted on engines of all ratings shall be subjected to the verification of CoP once for every 500 units per family or once a year, whichever is earlier</p> <p>Wherever applicable, RECDs fitted on engines of all ratings of engines shall be subjected to the verification of PCD once every CoP-year by PCD family (ies) representative RECD(s). Such demonstration is PCD family dependent and irrespective of combined volumes produced and sold under such family (ies)</p>

* As Applicable

Annexure-II

S No	Item Description	Parent RECD Type	RECD types within the RECD family (if applicable)					
		Type 1	Type 2	Type 3	Type 4	Type 5	Type 6	
1	Manufacturing Plant address	M/s.Chakr Innovation Private Limited, S.NO 236, Hissa No.7 & S.NO 237, Taluka Mulshi, Hinjewadi, Phase 1, Pune - 411 057, Maharashtra						
2	Manufacturer's trade name or mark	Chakr Innovation Private Limited						
3	RECD family designation	C2-R10						
4	RECD type/model designation	Chakr Shield 2.0 C2-CS1800-R10-V2	Chakr Shield 2.0 C2-CS1800-R9-V1	Chakr Shield 2.0 C2-CS1800-R9-V2	Chakr Shield 2.0 C2-CS1800-R9-V3	Chakr Shield 2.0 C2-CS1800-R9-V4	Chakr Shield 2.0 C2-CS1800-R9-V1.2	
5	RECD Category (Domestic/Imported)	Domestic						
6	Class of RECD	Class II						
7	Type Identification of the RECD	Continuous						
8	Location of type ID marking	Refer Specification no. CIPL/TA/C2-CS1800-R10 dtd. 07.11.2023 Clause no 1.8						
9	Identifying part number(s) of the RECD	C2-CS1800-R10-V2						
10	Engine/ Engine Family for which the RECD is intended (application range)	C15-2GP-1						
11	PM Reduction Efficiency of the RECD	75.56%						
12	Designed for fitment to an engine meeting the emissions requirements of (Regulation and Stage):	CPCB Stage -II						

ICAT Ref No.	2023-1463; IOCS No: 171435
Base Engine Type Approval Certificate number	ARAI/MoEF/DGTA/IMP/CIUSA-F2/2014-01-E1
Test Report Reference	CT0ET 0015 dt. 24/01/2024

AUTHORISED SIGNATORY	
	 SAURABH DALELA DIRECTOR
SITARAM KASHYAP DEPUTY GENERAL MANAGER	 Page 2 of 5