

TAC/Reference No. **C T O N T O O 5 6**

NT0056

TAC/Reference No.  
CTONT00NT0056M/s. JCBDate : 29<sup>th</sup> March, 2024

Cert	Report	Total
2	12	14 pgs

# CERTIFICATE

FOR  
TYPE APPROVAL FOR NOISE OF DIESEL GENSET

1	Name of Customer	M/s. JCB POWER PRODUCT INDIA PVT. LTD.			
2	Address of Customer	JCB H.O.:23/7, Mathura Road, Ballabgarh, 121004, Haryana, INDIA			
3	Manufacturer Name	Same as above			
4	Manufacturer Address	Same as above			
5	Generator Set Models	Base	Variant		
		G60QI	NIL		
6	Genset kVA Rating	58.5			
7	Engine TA/COP reference no. & Date	COSG00626 Dated 12 <sup>th</sup> Dcember 2023			
8	Engine Make & Models	JCB India Ltd. & JCB 444 TG4-55			
9	Engine Rating (kW)	55			
10	Engine Sr. No.	H00418796			
11	Type of Engine	Liquefied			
12	Type of Fuel	Diesel			
13	No. of Cylinders	4			
14	Rated speed, rpm	1500			
15	Cooling Mechanism	Liquefied			
16	Method of Aspiration	Turbocharged & intercooled (TCIC)			
17	Details of Quality Management System (QMS)	Type of QMS	Certifying Agency	Certificate No.	Valid Up to
		CPCB Guidelines	ICAT	CTONT0056	31/Dec/24
18	Approval	✓			
<b>Granted/ Not Granted/ Extended</b>					

Based on the verification of the documents and tests conducted on the genset models manufactured by M/s. JCB POWER PRODUCT INDIA PVT. LTD. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph1&3) of schedule I of the Environment (Protection) Rules, 1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference	CETNJCBPTCNVH174722	Please turn over for DISCLAIMER
----------------	---------------------	---------------------------------

<b>AUTHORISED SIGNATORY</b>	
-----------------------------	--

IKSHIT SHRIVASTAVA Manager	RAKESH K Asst. General Manager	SAURABH DALELA Director	

			Page 1 of 2
--	--	--	-------------