



| | | | | | |
|---|---|---|---|------|-----|
| C | O | T | G | 0136 | E01 |
|---|---|---|---|------|-----|

Date : 28th June 2024**COP Annexure-I**




| Criteria* | COP Required |
|--|--|
| RECD Manufacturer/Importer/Retrofitter | <p>RECDs fitted on engines of all ratings shall be subjected to the verification of CoP once for every 500 units per family or once a year, whichever is earlier</p> <p>Wherever applicable, RECDs fitted on engines of all ratings of engines shall be subjected to the verification of PCD once every CoP-year by PCD family (ies) representative RECD(s). Such demonstration is PCD family dependent and irrespective of combined volumes produced and sold under such family (ies)</p> |

* As Applicable

Annexure-II

| S No | Item Description | Parent RECD Type | RECD types within the RECD family (if applicable) |
|------|---|---|---|
| | | | Type 1 |
| 1 | Manufacturing Plant address | M/s Chakr Innovation Private Limited, Survey No. 236 & 237, Hissa No.7, Taluka - Mulshi, Rajiv Gandhi Infotech Park, Hinjewadi Phase -1, Pune, Maharashtra - 411057 | |
| 2 | Manufacturer's trade name or mark | Chakr Innovation Private Limited | |
| 3 | RECD family designation | C2-R8 | |
| 4 | RECD type/model designation | C2-CS1800-R8 | C2-CS1800-R6 |
| 5 | RECD Category (Domestic/Imported) | Domestic | |
| 6 | Class of RECD | Class II | |
| 7 | Type Identification of the RECD | Continuous | |
| 8 | Location of type ID marking | Refer Specification no. CIPL/TA/C2-CS1800-R8 dtd. 17.06.2024 Clause no 1.8 | |
| 9 | Identifying part number(s) of the RECD | C2-CS1800-R8-V2.3 | C2-CS1800-R6-V2.3 |
| 10 | Engine/ Engine Family for which the RECD is intended (application range) | DV8TA G1 | |
| 11 | PM Reduction Efficiency of the RECD | 79.39% | |
| 12 | Designed for fitment to an engine meeting the emissions requirements of (Regulation and Stage): | CPCB Stage -II | |

| | |
|--|--------------------------------------|
| ICAT Ref No. | 2024-0314; IOCS No: 176909 |
| Base Engine Type Approval Certificate number | ARAI/MoEF/DGTA/KOEL-F115/2014-01 |
| Test Report Reference | CT0ET 0221.E01 ET0249 dt. 27/06/2024 |

| AUTHORISED SIGNATORY | |
|---|--|
|  |  SAURABH DALELA DIRECTOR |
| SITARAM KASHYAP DEPUTY GENERAL MANAGER |  Page 2 of 6 |