

TAC/Reference No. **C T O N T O 1 5 9**Date : Date : 21st Oct, 2024TAC/Reference No. **CTONT015 M/s.**
Mass Generators Pvt. L**CERTIFICATE**FOR
TYPE APPROVAL FOR NOISE OF DIESEL GENSET

| Cert | Report | Total |
|------|--------|--------|
| 2 | 10 | 12 pgs |



| | | | | |
|---------------------------------------|--|--|-------------------|-----------------|
| 1 | Name of Customer | M/s. Mass Generators Pvt. Ltd. | | |
| 2 | Address of Customer | SIDCO Industrial Complex, Old Railway Station Road, Kathua Jammu & Kashmir – Pin Code-184001 | | |
| 3 | Manufacturer Name | Same as above | | |
| 4 | Manufacturer Address | Same as above | | |
| 5 | Generator Set Models | Base | Variant | |
| | | MAAS/60/SP/TP | NA | |
| 6 | Genset kVA Rating | 60 | NA | |
| 7 | Engine TA/COP reference no. & Date | CCTG0178 Dated 23 th August 2024 | | |
| 8 | Engine Make & Models | TAFE MOTORS AND TRACTORS LIMITED and 333W0-EG060 | | |
| 9 | Engine Rating (kW) | 55 | | |
| 10 | Engine Sr. No. | 534522996415 | | |
| 11 | Type of Engine | 4-Stroke, 3 Cylinder, Liquid Cooled | | |
| 12 | Type of Fuel | Diesel | | |
| 13 | No. of Cylinders | 3 | | |
| 14 | Rated speed, rpm | 1500 | | |
| 15 | Cooling Mechanism | Liquid Cooled | | |
| 16 | Method of Aspiration | Turbocharger and Intercooler | | |
| 17 | Details of Quality Management System (QMS) | Type of QMS | Certifying Agency | Certificate No. |
| | | CPCB Guidelines | ICAT | CTONT0159 |
| 18 | Approval | √ | | |
| Granted/ Not Granted/ Extended | | | | |

Based on the verification of the documents and tests conducted on the Genset Model MAAS/60/SP/TP, manufactured and submitted by M/s. Mass Generators Pvt. Ltd., it is certified that the following generator set models comply with the provisions of the Environment (Protection) Rules, 1986 vide notification no. G.S.R. 742(E), dated 25th September, 2000 at serial no. 91 and its amendment vide G.S.R. 628(E) dated 30th August, 2001 and G.S.R. 535(E) dated 07th August, 2013 issued by Ministry of Environment and Forests, Government of India.

| | | |
|----------------|--------------------|---------------------------------|
| ICAT Reference | CETNMASTLNVH180621 | Please turn over for DISCLAIMER |
|----------------|--------------------|---------------------------------|

AUTHORISED SIGNATORY

| | | |
|--------------------------------------|--|-----------------------------------|
| | | |
| IKSHIT SHRIVASTAVA Manager | RAKESH KUMAR Asst. General Manager | SAURABH DALELA Director |
| | | Page 1 of 2 |