

TAC/Reference No. **C T O N T O 1 5 3**Date : 11<sup>th</sup> October 2024TAC/Reference No. **CTONT015M/s.**  
**HIMALAYAN POWER M**

# CERTIFICATE

FOR  
TYPE APPROVAL FOR NOISE OF PETROL GENSET

Cert	Report	Total
2	10	12 pgs



1	Name of Customer	M/s. HIMALAYAN POWER MACHINE MFG. CO.		
2	Address of Customer	Part of Khasra No 51 & 52 KA, Vill.-Kuanwala, Haridwar Road, Dehradun, Dehradun-248001, Uttarakhand, INDIA		
3	Manufacturer Name	Same as above		
4	Manufacturer Address	Same as above		
5	Generator Set Models	Base	Variant	Variant
		HP 75 is	HP 55 is	HP 70 is
6	Genset kVA Rating	6.5	5	5.5
7	Engine TA/COP reference no. & Date	COTG0157 Dated 18 <sup>th</sup> July 2024		
8	Engine Make & Models	M/s. HIMALAYAN POWER & HM 192 PY4		
9	Engine Rating (kW)	6.5		
10	Engine Sr. No.	220105244		
11	Type of Engine	Air Cooled		
12	Type of Fuel	Petrol		
13	No. of Cylinders	1		
14	Rated speed, rpm	3000		
15	Cooling Mechanism	Air Cooled		
16	Method of Aspiration	Naturally Aspirated		
17	Details of Quality Management System (QMS)	Type of QMS	Certifying Agency	Certificate No.
		CPCB Guidelines	ICAT	CTONT0153
18	Approval	√		
		Granted/ Not Granted/ Extended		

Based on the verification of the documents and tests conducted on the Genset Model HP 75is manufactured and submitted by M/s. Himalayan Power Machine Mfg. Co., it is certified that the following generator set models comply with the provisions of the Environment (Protection) Rules, 1986 vide notification no. G.S.R. 742(E), dated 25th September, 2000 at serial no. 91 and its amendment vide G.S.R. 628(E) dated 30th August, 2001 and G.S.R. 535(E) dated 07th August, 2013 issued by Ministry of Environment and Forests, Government of India.

ICAT Reference	CETNHPMMTKNVH179973	Please turn over for DISCLAIMER
----------------	---------------------	---------------------------------

**AUTHORISED SIGNATORY**

<b>IKSHIT SHRIVASTAVA</b> Manager	<b>RAKESH KUMAR</b> Asst. General Manager	<b>SAURABH DALELA</b> Director