



C O U G 0008

Date : 10th January 2025

COP Annexure-I



Criteria*	COP Required
RECD Manufacturer/Importer/Retrofitter	<p>RECDs fitted on engines of all ratings shall be subjected to the verification of CoP once for every 500 units per family or once a year, whichever is earlier</p> <p>Wherever applicable, RECDs fitted on engines of all ratings of engines shall be subjected to the verification of PCD once every CoP-year by PCD family (ies) representative RECD(s). Such demonstration is PCD family dependent and irrespective of combined volumes produced and sold under such family (ies)</p>

* As Applicable

Annexure-II

S No	Item Description	Parent RECD Type
		Type 1
1	Manufacturing Plant address	M/s Vasthi Instruments Pvt. Ltd., Plot No. 21 & 22, Block No. 24, Phase -4, Auto Nagar, Guntur - 522001, Andhra Pradesh
2	Manufacturer's trade name or mark	M/s Vasthi Instruments Pvt. Ltd.
3	RECD family designation	FEVERECD-7200
4	RECD type/model designation	VE-REF-7200-125
5	RECD Category (Domestic/Imported)	Domestic
6	Class of RECD	Class II
7	Type Identification of the RECD	Continuous
8	Location of type ID marking	Refer Specification no. VIPL/RECD/21/11/24 dtd. 05/12/2024 Clause no 1.8
9	Identifying part number(s) of the RECD	VE-REF-7200-125
10	Engine/ Engine Family for which the RECD is intended (application range)	Tested Engine Model : QSB 5.9-G1 Application Range: 40kW to 137.2kW (Refer Annexure-III)
11	PM Reduction Efficiency of the RECD	98.25%
12	Designed for fitment to an engine meeting the emissions requirements of (Regulation and Stage)	CPCB Stage -II

ICAT Ref No.	2024-1468; IOCS No: 181989
Base Engine Type Approval Certificate number	ARAI/MoEF/DGTA/CILP-F40/2014-21
Test Report Reference	CT0EU 0003 dt. 07/01/2025

AUTHORISED SIGNATORY	
 SITARAM KASHYAP DEPUTY GENERAL MANAGER	 SAURABH DALELA DIRECTOR

