



TAC/Reference No. **C T O N U 0 0 4 1**

Date : 18th February 2025

TAC/Reference No. **CTONU004 M/s. MAAS Generators Pvt. Ltd**

CERTIFICATE

Cert	Report	Total
2	11	13 pgs

FOR

TYPE APPROVAL FOR NOISE OF DIESEL GENSET



1	Name of Customer	M/s. MAAS Generators Pvt. Ltd.		
2	Address of Customer	SIDCO Industrial Complex, Old Railway Station Road ,Kathua Jammu & Kashmir - Pin Code-184001		
3	Manufacturer Name	Same as above		
4	Manufacturer Address	Same as above		
5	Generator Set Models	Base	Variant	
		MAAS/25/SP/TP	MAAS/20/SP/TP	
6	Genset kVA Rating	25	20	
7	Engine TA/COP reference no. & Date	CCTG0177 Dated 23 th August 2024		
8	Engine Make & Models	TAFE MOTORS AND TRACTORS LIMITED and 329A0-EG025		
9	Engine Rating (kW)	25.5		
10	Engine Sr. No.	534725834524		
11	Type of Engine	4-Stroke, 3 Cylinder, Air Cooled		
12	Type of Fuel	Diesel		
13	No. of Cylinders	3		
14	Rated speed, rpm	1500		
15	Cooling Mechanism	Air Cooled		
16	Method of Aspiration	Turbocharger and Intercooler		
17	Details of Quality Management System (QMS)	Type of QMS	Certifying Agency	Certificate No.
		CPCB Guidelines	ICAT	CTONU0041
18	Approval	√		
Granted/ Not Granted/ Extended				

Based on the verification of the documents and tests conducted on the genset model MAAS/25/SP/TP manufactured by M/s.MAAS Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph1&3) of schedule I of the Environment (Protection) Rules,1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference CETNMASSUANVH182841 Please turn over for DISCLAIMER

AUTHORISED SIGNATORY

 ANJANA KUMARI Sr.Engineer	 IKSHIT SHRIV. Manager	 SAURABH DALELA Director	 Page 1 of 2
--	---	---	---