

TAC/Reference No. C T 0 N U 0 0 3 9

CERTIFICATE

Date::19thFebuary 2025

Cert	Report	Total				
2	11	13 pgs				

FOR TYPE APPROVAL FOR NOISE OF DIESEL GENSET

Non- Transferable

1	Name of Customer	M/s. MAAS Genera	M/s. MAAS Generators Pvt. Ltd.				
2	Address of Customer	SIDCO Industrial C – Pin Code-184001	SIDCO Industrial Complex,Old Railway Station Road ,Kathua Jammu & Kashmir – Pin Code-184001				
3	Manufacturer Name	Same as above	Same as above				
4	Manufacturer Address	Same as above	Same as above				
5	Generator Set Models	MAA	Base MAAS/10/SP/TP		Variant MAAS/7.5/SP/TP		
6	Genset kVA Rating		10		7.5		
7	Engine TA/COP reference no. & Date	CCUG0035 Dated 0	CCUG0035 Dated 01th February 2025				
8	Engine Make & Models	TAFE MOTORS AN	TAFE MOTORS AND TRACTORS LIMITED and 115A0-EG010				
9	Engine Rating (kW)	13	13				
10	Engine Sr. No.	534723936842	534723936842				
11	Type of Engine	4-Stroke, 1 Cylinder,	4-Stroke, 1 Cylinder, Air Cooled				
12	Type of Fuel	Diesel	Diesel				
13	No. of Cylinders	1	1				
14	Rated speed, rpm	1500	1500				
15	Cooling Mechanism	Air Cooled	Air Cooled				
16	Method of Aspiration	Turbocharger and In	Turbocharger and Intercooler				
17	Details of Quality Management System	Type of QMS	Certifying Agency	Certificate No.	Valid Up to		
	(QMS)	CPCB Guidelines	ICAT	CT0NU0039	12/31/2025		
18	Approval		<u> </u>				
			Granted/ Not Granted/ Extended				

Based on the verification of the documents and tests conducted on the genset model MAAS/10/SP/TP manufactured by M/s.MAAS Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph1&3) of schedule I of the Environment (Protection) Rules, 1986. (Noise limit for diesel generator sets upto 800 kW).

	CAT Reference	CETNMASSUANVH182840	Please turn over for DISCLAII	MER	
Α	UTHORISED SIGNATORY				
			THE FOR AUTOMODIAL TECHNICAL TECHNIC		
	ANJANA KUMARI	IKSHIT SHRIVASTAVA	THE STATE OF THE S	SAURABH DALELA	Page
	FORTYPEAPPROVALFON SIZE DISTRIBUTION OF THE TOTAL SAME ASSESSMENT OF THE T	Manager	* MANESAR * IT	Director	2