

TAC/Reference No. C T 0 N U 0 0 4 1

TAC/Reference No. CT0NU004 M/s MAAS Generators Pvt. Ltd

CERTIFICATE

 Date:: 18thFebuary 2025

 Cert
 Report
 Total

 2
 11
 13 pgs

FOR

TYPE APPROVAL FOR NOISE OF DIESEL GENSET

1	Name of Customer	M/s. MAAS Generators Pvt. Ltd.
ALO Ž	Address of Customer	SIDCO Industrial Complex,Old Railway Station Road ,Kathua Jammu & Kashr – Pin Code-184001
3	Manufacturer Name	Same as above
4	Manufacturer Address	Same as above
5 10	Generator Set Models	Base Variant MAAS/25/SP/TP MAAS/20/SP/TP
£ 6	Genset kVA Rating	25 20
7	Engine TA/COP reference no. & Date	CCTG0177 Dated 23 th August 2024
8 💉	Engine Make & Models	TAFE MOTORS AND TRACTORS LIMITED and 329A0-EG025
9 🗞	Engine Rating (kW)	25.5 (2 ¹) (2 ¹) (10 ¹) (10 ¹)
10	Engine Sr. No.	534725834524
11	Type of Engine	4-Stroke, 3 Cylinder, Air Cooled
12	Type of Fuel	Diesel No. 100
13	No. of Cylinders	3 Not the state of
14	Rated speed, rpm	1500 Me
15	Cooling Mechanism	Air Cooled
16	Method of Aspiration	Turbocharger and Intercooler
17	Details of Quality Management System (QMS)	Type of QMS Certifying Agency Certificate No. Valid Up to CPCB Guidelines ICAT CT0NU0041 12/31/2025
18	Approval	

Based on the verification of the documents and tests conducted on the genset model MAAS/25/SP/TP manufactured by M/s.MAAS Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph1&3) of schedule I of the Environment (Protection) Rules, 1986. (Noise limit for diesel generator sets upto 800 kW).

