



CTON U0039

TAC/Reference No.

C	T	O	N	U	0	0	3	9
---	---	---	---	---	---	---	---	---

Date : 19th Feb. 2025

Cert	Report	Total
2	11	13 pgs

CERTIFICATE FOR TYPE APPROVAL FOR NOISE OF DIESEL GENSET

Non- Transferable

1	Name of Customer	M/s. MAAS Generators Pvt. Ltd.			
2	Address of Customer	SIDCO Industrial Complex,Old Railway Station Road ,Kathua Jammu & Kashmir – Pin Code-184001			
3	Manufacturer Name	Same as above			
4	Manufacturer Address	Same as above			
5	Generator Set Models	Base	Variant		
		MAAS/10/SP/TP	MAAS/7.5/SP/TP		
6	Genset kVA Rating	10	7.5		
7	Engine TA/COP reference no. & Date	CCUG0035 Dated 01 th February 2025			
8	Engine Make & Models	TAFE MOTORS AND TRACTORS LIMITED and 115A0-EG010			
9	Engine Rating (kW)	13			
10	Engine Sr. No.	534723936842			
11	Type of Engine	4-Stroke, 1 Cylinder, Air Cooled			
12	Type of Fuel	Diesel			
13	No. of Cylinders	1			
14	Rated speed, rpm	1500			
15	Cooling Mechanism	Air Cooled			
16	Method of Aspiration	Turbocharger and Intercooler			
17	Details of Quality Management System (QMS)	Type of QMS	Certifying Agency	Certificate No.	Valid Up to
		CPCB Guidelines	ICAT	CT0NU0039	12/31/2025
	Approval	√			
		Granted/ Not Granted/ Extended			

Based on the verification of the documents and tests conducted on the genset model MAAS/10/SP/TP manufactured by M/s. MAAS Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph 1&3) of schedule I of the Environment (Protection) Rules, 1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference		GETNMASSUANVH182840		Please turn over for DISCLAIMER	
AUTHORISED SIGNATORY					
ANJANA KUMARI Sr. Engineer		IKSHIT SHRIVASTAVA Manager		SAURABH DALELA Director	
				Page 1 of 2	