



CTON U 0037

TAC/Reference No. C T O N U 0 0 3 7

Date : 18th Feb. 2025

Cert	Report	Total
2	11	13 pgs

CERTIFICATE FOR TYPE APPROVAL FOR NOISE OF DIESEL GENSET

(up to 800kw)

Non- Transferable

1	Name of Customer	M/s. MAAS Generators Pvt. Ltd.			
2	Address of Customer	SIDCO Industrial Complex,Old Railway Station Road ,Kathua Jammu & Kashmir – Pin Code-184001			
3	Manufacturer Name	Same as above			
4	Manufacturer Address	Same as above			
5	Generator Set Models	Base	Variant		
6	Genset kVA Rating	MAAS/7.5/SP/TP	MAAS/5/SP/TP		
7	Engine TA/COP reference no. & Date	7.5	5		
8	Engine Make & Models	COTG0160 Dated 18th JULY 2024			
9	Engine Rating (kW)	TAFE MOTORS AND TRACTORS LIMITED and 110A0-EG008			
10	Engine Sr. No.	8.3			
11	Engine Sr. No.	534623835412			
12	Type of Engine	4-Stroke, 1 Cylinder, Air Cooled			
13	Type of Fuel	Diesel			
14	No. of Cylinders	1			
15	Rated speed, rpm	1500			
16	Cooling Mechanism	Air Cooled			
17	Method of Aspiration	Turbocharger and Intercooler			
17	Details of Quality Management System (QMS)	Type of QMS	Certifying Agency	Certificate No.	Valid Up to
		CPCB Guidelines	ICAT	CT0NU0037	12/31/2025
	Approval	√			
		Granted/ Not Granted/ Extended			

Based on the verification of the documents and tests conducted on the genset model MAAS/7.5/SP/TP manufactured by M/s. MAAS Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph 1&3) of schedule I of the Environment (Protection) Rules, 1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference		CETNMASSUANVH72537		Please turn over for DISCLAIMER	
AUTHORISED SIGNATORY					
CTONU0037e:18thFeb.2025serReportTotalupto800kw/Non-TransferableM/s.MAASGen		CTONU0037e:18thFeb.2025serReportTotalupto800kw/Non-TransferableM/s.MAASGen		CTONU0037e:18thFeb.2025serReportTotalupto800kw/Non-TransferableM/s.MAASGen	
ANJANA KUMARI Sr. Engineer		IKSHIT SHRIVASTAVA Manager		SAURABH DALELA Director	
Page 1 of 2		Page 1 of 2		Page 1 of 2	