

TAC/Reference No. **C T O N U 0 0 3 9**Date : 19th February 2025**CERTIFICATE**

Cert	Report	Total
2	11	13 pgs

CER

**FOR
TYPE APPROVAL FOR NOISE OF DIESEL GENSET****Non- Transferable**

		M/s. MAAS Generators Pvt. Ltd.			
2	Address of Customer	SIDCO Industrial Complex, Old Railway Station Road, Kathua Jammu & Kashmir – Pin Code-184001			
3	Manufacturer Name	Same as above			
4	Manufacturer Address	Same as above			
5	Generator Set Models	Base	Variant		
6	Genset kVA Rating	MAAS/10/SP/TP	MAAS/7.5/SP/TP		
7	Engine TA/COP reference no. & Date	10	7.5		
8	Engine Make & Models	CCUG0035 Dated 01th February 2025			
9	Engine Rating (kW)	TAFE MOTORS AND TRACTORS LIMITED and 115A0-EG010			
10	Engine Sr. No.	13			
11	Type of Engine	534723936842			
12	Type of Fuel	4-Stroke, 1 Cylinder, Air Cooled			
13	No. of Cylinders	Diesel			
14	Rated speed, rpm	1			
15	Cooling Mechanism	1500			
16	Method of Aspiration	Air Cooled			
17	Details of Quality Management System (QMS)	Type of QMS	Certifying Agency	Certificate No.	Valid Up to
18	Approval	CPCB Guidelines	ICAT	CTONU0039	12/31/2025
		Granted/ Not Granted/ Extended			

Based on the verification of the documents and tests conducted on the genset model MAAS/10/SP/TP manufactured by M/s. MAAS Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph 1&3) of schedule I of the Environment (Protection) Rules, 1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference	CETNMASSUANVH182840	Please turn over for DISCLAIMER
-----------------------	----------------------------	--

AUTHORISED SIGNATORY

			
ANJANA KUMARI Sr.Engineer	IKSHITA SHRIVASTAVA Manager	SAURABH DALELA Director	ICAT Innovation • Service • Excellence