


TAC/Reference No. **C T O N U 0 0 4 1**

CTON U0041

Date : 18th Feb. 2025

Cert	Report	Total
2	11	13 pgs

**CERTIFICATE FOR
TYPE APPROVAL FOR NOISE OF DIESEL GENSET****Non- Transferable**

1	Name of Customer	M/s. MAAS Generators Pvt. Ltd.			
2	Address of Customer	SIDCO Industrial Complex,Old Railway Station Road ,Kathua Jammu & Kashmir – Pin Code-184001			
3	Manufacturer Name	Same as above			
4	Manufacturer Address	Same as above			
5	Generator Set Models	Base		Variant	
6	Genset kVA Rating	MAAS/25/SP/TP		MAAS/20/SP/TP	
7	Engine TA/COP reference no. & Date	25		20	
8	Engine Make & Models	CCTG0177 Dated 23 th August 2024			
9	Engine Rating (kW)	TAFE MOTORS AND TRACTORS LIMITED and 329A0-EG025			
10	Engine Sr. No.	25.5			
11	Type of Engine	534725834524			
12	Type of Fuel	4-Stroke, 3 Cylinder, Air Cooled			
13	No. of Cylinders	Diesel			
14	Rated speed, rpm	3			
15	Cooling Mechanism	1500			
16	Method of Aspiration	Air Cooled			
17	Details of Quality Management System (QMS)	Turbocharger and Intercooler			
	Approval	Type of QMS	Certifying Agency	Certificate No.	Valid Up to
		CPCB Guidelines	ICAT	CT0NU0041	12/31/2025
		✓			
		Granted/ Not Granted/ Extended			

Based on the verification of the documents and tests conducted on the genset model MAAS/25/SP/TP manufactured by M/s. MAAS Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph 1&3) of schedule I of the Environment (Protection) Rules, 1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference	CETNMASSUANVH182841	Please turn over for DISCLAIMER
----------------	---------------------	---------------------------------

AUTHORISED SIGNATORY

ANJANA KUMARI Sr. Engineer	IKSHIT SHRIVASTAVA Manager			
		SAURABH DALELA Director		Page 1 of 2