



[National Automotive Board (NAB)]

CCTG 0261


CTG0261

Date : 24th December 2024

| Cert | Report | Total |
|------|--------|--------|
| 01 | 05 | 06 Pgs |

CERTIFICATE

FOR
CONFORMITY OF PRODUCTION



M/s. Captiva Energy Solutions Private Ltd

Plant: Paraganas, West Bengal

1. Based on the verification of documents and trials conducted on the engine model(s) "G25.8L" manufactured by M/s. Generac Power Systems Inc, Wisconsin, USA and imported & supplied by M/s. Captiva Energy Solutions Private Ltd., Village-Sanjua, PO Bakarhat, PS Bibirhat, South 24 Paraganas, West Bengal-743 377 randomly selected from their plant at West Bengal, it is certified that the following dedicated NG driven engine model of family Generac G25.8L comply with the provisions of Verification of the Conformity of Production (CoP) as per para 5.0 of CPCB procedure (System & Procedure for compliance to emission limits for dedicated NG (upto 800 kW) for genset application) and Rules notified by Ministry of Environment, Forest and Climate Change (MoEFCC), Govt. of India.




| Notification No. | Date | Rule No. | Import Category |
|------------------|------------|--|-----------------|
| GSR 804 (E) | 03.11.2022 | Rule 88 of Environment (Protection) Rules, 2022 (Third Amendment) | |

2. This certificate covers the genset engine families and its models as listed in below table, declared by the manufacturer to have been produced / planned to be produced, during the stipulated period.

| Plant | Manufacturer | Engine Power | Cubic Capacity(cm ³) |
|----------------|-------------------------------|--------------------------------|----------------------------------|
| Wisconsin, USA | M/s.Generac Power Systems Inc | 462 kW @ 1500 rpm | 26275 |
| Engine Family | Generac G25.8L | Manufacturing Period | COP Year |
| Parent | G25.8L | 01/07/2023 to 30/06/2024 | 2023 to 2024 |
| Variant (s) | NIL | | |

3 Next CoP test shall be carried out before 01st July 2025 (i.e. once in a year) or after production of every 1000 units for the above family, whichever is earlier.

| | | |
|---|---------------------------|---------------------------------|
| Type approval certificate no. for reference | CO5G 0598 dt. 19/10/2023 | |
| COP Report Reference | CC0ET 0490 Dt. 23.12.2024 | |
| ICAT Case Reference | IOCS No. 176847 | Please turn over for DISCLAIMER |

| | | |
|---|--|---|
| AUTHORISED SIGNATORY | | |
|  |  |  |
| SITARAM KASHYAP DEPUTY GENERAL MANAGER | SAURABH DALELA DIRECTOR | Page 1 of 1 |