

TAC/Reference No. **C T O N U 0 0 3 9**Date : 19<sup>th</sup> February 2025TAC/Reference No. **CTON U003****CERTIFICATE****FOR  
TYPE APPROVAL FOR NOISE OF DIESEL GENSET**

Cert	Report	Total
2	11	13 pgs



1	Name of Customer	M/s. MAAS Generators Pvt. Ltd.			
2	Address of Customer	SIDCO Industrial Complex,Old Railway Station Road ,Kathua Jammu & Kashmir – Pin Code-184001			
3	Manufacturer Name	Same as above			
4	Manufacturer Address	Same as above			
5	Generator Set Models	Base		Variant	
		MAAS/10/SP/TP		MAAS/7.5/SP/TP	
6	Genset kVA Rating	10		7.5	
7	Engine TA/COP reference no. & Date	CCUG0035 Dated 01 <sup>th</sup> February 2025			
8	Engine Make & Models	TAFE MOTORS AND TRACTORS LIMITED and 115A0-EG010			
9	Engine Rating (kW)	13			
10	Engine Sr. No.	534723936842			
11	Type of Engine	4-Stroke, 1 Cylinder, Air Cooled			
12	Type of Fuel	Diesel			
13	No. of Cylinders	1			
14	Rated speed, rpm	1500			
15	Cooling Mechanism	Air Cooled			
16	Method of Aspiration	Turbocharger and Intercooler			
17	Details of Quality Management System (QMS)	Type of QMS	Certifying Agency	Certificate No.	Valid Up to
		CPCB Guidelines	ICAT	CTONU0039	12/31/2025
18	Approval	✓			
		Granted/ Not Granted/ Extended			

Based on the verification of the documents and tests conducted on the genset model MAAS/10/SP/TP manufactured by M/s. MAAS Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph 1&3) of schedule I of the Environment (Protection) Rules, 1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference **GETNMASSUANVH182840** Please turn over for DISCLAIMER**AUTHORISED SIGNATORY**

				
<b>ANJANA KUMARI</b> Sr.Engineer	<b>IKSHIT SHRIVAS</b> Manager	<b>SAURABH DALELA</b> Director		

