[National Automotive Board (NAB)]

C	C	Т	G	0214

CERTIFICATE

OF

CONFORMITY OF PRODUCTION (CoP) FOR THE YEAR 2023-24

for

Retro-fit Emission Control Devices (RECD) Compliance to Diesel Power Generating Set Engines

M/s Vasthi Instruments Pvt. Ltd.

Plant:Guntur, Andhra Pradesh

1. Based on the verification of documents and trials conducted on RECD model(s) "FEVERECD-7200-250 KVA" (Family FEVERECD-7200) manufactured by M/s Vasthi Instruments Pvt. Ltd., randomly selected from their plant at Guntur, Andhra Pradesh, it is certified that the following Retrofit Emission Control Devices model of family FEVERECD-7200 complies with the provisions of Verification of the Conformity of Production (CoP) as per para 5.0 of System & Procedure (PCLS/12/2021-22) for Compliance to Diesel Power Generating Set Engines Up to Gross Mechanical Power 800 kW, as Per NGT Order/report "Report filed in O.A. No. 681/2018 dated 6.08.2019".

Notification No.	Date
CPCB-PCLS/12/2021-22	01.02.2022

2 This certificate covers the Retrofit Emission Control Devices families and its models as listed in below table, declared by the manufacturer to have been produced / planned to be produced, during the stipulated period.

	Fuel	Plant	Manufac	turer	Engine Power		Cubic Capacity (cm³)	
	Diesel	Guntur, Andhra Pradesh M/s Vasthi Instruments Pvt. Ltd. 183 kW			@ 1500 rpm		8860	
	RECD Family	FEVERECD-7200				Manufacturing Period		COP Year
	Parent	FEVERECD-7200-250 KVA			01/07/2023 to 30/06/2024		2023 to 2024	
S. No.	Item Description	Annexure-I						
Engine Baseline emissions		CPCB Stage -II Class of RECD		RECD	Class II			

3. Next CoP test shall be carried out before 01st July 2025 (i.e. once in a year) or after production of every 500 units for the above family, whichever is earlier.

Type approval certificate no. for reference	COTG 0048 dt	t. 04/03/2024			
COP Report Reference	CC0ET 0388 Dt. 15.10.2024				
ICAT Case Reference	IOCS NO. 179945			Please turn over for DISCLAIMER	
AUTHORISED SIGNATORY					
SITARAM KASHYAP			SAUR	ABH DALELA	Page 1 of
DEPUTY GENERAL MANAGER			D	IRECTOR	2