[National Automotive Board (NAB)]

C	С	T	G	0228

CERTIFICATE

OF

CONFORMITY OF PRODUCTION (CoP) FOR THE YEAR 2023-24

Retro-fit Emission Control Devices (RECD) Compliance to Diesel Power Generating Set Engines

Date: 05th November 2024 Cert Report 05

07 pgs

02

M/s Chakr Innovation Pvt. Ltd.

Plant:Hinjewadi, Pune

1. Based on the verification of documents and trials conducted on RECD model(s) "C2-CS1800-R12" (Family C2-R12) manufactured by M/s. Chakr Innovation Pvt. Ltd., randomly selected from their plant at Hinjewadi, Pune, it is certified that the following Retrofit Emission Control Devices model of family C2-R12 complies with the provisions of Verification of the Conformity of Production (CoP) as per para 5.0 of System & Procedure (PCLS/12/2021-22) for Compliance to Diesel Power Generating Set Engines Up to Gross Mechanical Power 800 kW, as Per NGT Order/report "Report filed in O.A. No. 681/2018 dated 6.08.2019".

Notification No.	Date		
CPCB-PCLS/12/2021-22	01.02.2022		

This certificate covers the Retrofit Emission Control Devices families and its models as listed in below table, declared by the manufacturer to have been produced / planned to be produced, during the stipulated period.

Fuel		Plant	Manufac	turer	Engine Power		Cubic Capacity (cm³)		
Diesel		Hinjewadi, Pune	M/s Chakr Innova	ition Pvt. Ltd.	797.0 kW	797.0 kW @ 1500 rpm		38000	
RECD Family		C2-R12			Manufacturing Period		COP Year		
Parent		C2-CS1800-R12			01/07/2023 to		2023		
S. No.	Item Description	Annexure-I			30/06/2024		to 2024		
Engine Baseline emissions		CPCB Stage -II Class of I		RECD	Class II				

3. Next CoP test shall be carried out before 01st July 2025 (i.e. once in a year) or after production of every 500 units for the above family, whichever is earlier.

Type approval certificate no. for reference	COTG 0012 d	t. 11/01/2024			
COP Report Reference	CC0ET 0420 [ot. 28.10.2024			
ICAT Case Reference	IOCS NO. 177177			Please turn over for DISCLAIMER	
AUTHORISED SIGNATORY					
SITARAM KASHYAP			SAUR	ABH DALELA	Page 1 of
DEPUTY GENERAL MANAGER			DI	RECTOR	2