[National Automotive Board (NAB)]

C O T G 0234

TYPE APPROVAL CERTIFICATE Cert Rep

 Date: 14th November 2024

 Cert
 Report
 Specs
 Drg
 Total

 02
 04
 13
 06
 25 pgs

COMPLIANCE TO MASS EMISSION NORMS FOR DEDICATED NG Engine (upto 800 kW)

1. In order to establish compliance to the provisions of mass emission limits, applicable as on date, documental verification / necessary testing was carried out, on the following engine model(s), submitted by the engine **manufacturer/supplier** referred below:

This Certificate Supercedes	Engine Manufacturer					
Current Certificate	M/s Generac Power Systems Inc. S45W29290, WI-59, Waukesha, WI 53189 Plant: Wisconsin, USA					
Engine Family	Engine Sup	plier (Manufacturer / Impo	orter)			
Generac G9.0L TC	M/s Captiva Energy Solutions Pvt. Ltd., Bibirhat, Village Sanjua, PO Bakrahat, PS Bishnupur, South 24 Parganas, West Bengal - 743377					
Parent Engine		Cubic Capacity (cm³)	Gross Engine Powe	Compliance of Norms w.e.f		
G9L TA		8865	158.0 kW @ 1500 rp	m 01.07.2023		
Variant(s)		NIL				

2. Validity of the Certificate

	1	The validity of existing emission norms under Notification No. GSR 804(E) dt. 03.11.2022 or until further amendment in the MoEFCC rule, whichever is earlier.	
This Type Approval Certificate is valid till	2	No change in technical specification of the engine specified	
This Type Approval Certificate is valid till	3	Explicitly the Type Approval Certificate withdrawn by the engine supplier	
	4	Till COP is not missed / Till COP procedure compliance as per CPCB Administrative Procedure is obtained within prescribed time frame.	

3. It is certified that the above **NG engine model(s)** comply with the emission limits for Genset Engines powered by SI engines under power category (56<P≤560)kW, as prescribed under the following rules, notified by **Ministry of Environment, Forest and Climate Change (MoEFCC), Govt. of India:**

Rule No.	Description	Notification	Date
Environment (Protection) Rule, 1986 in the schedule I, Serial number 88	Emission limits for new engines used for power generating set (Genset) application upto 800 kW Gross Mechnical Power	GSR 804 (E)	03.11.2022

4. COP:

COP will be applicable as per CPCB Procedure, for details refer **COP-Annexure**.

Please turn over for Disclaimer

AUTHORISED SIGNATORY		
SITARAM KASHYAP	SAURABH DALELA	Page 1 of
DEPUTY GENERAL MANAGER	DIRECTOR	2