## [National Automotive Board (NAB)]

C O T G 0235

## TYPE APPROVAL CERTIFICATE

.

| Date: 27 <sup>th</sup> November 2024 |        |       |     |        |  |
|--------------------------------------|--------|-------|-----|--------|--|
| Cert                                 | Report | Specs | Drg | Total  |  |
| 6                                    | 10     | 63    | 2   | 81 pgs |  |

## FOR Retro-fit Emission Control Devices (RECD) Compliance

1. Based on the verification of documents & trials conducted on RECD model "C03 NB-HF" (Family designation R3) for below mentioned manufacturer and it is certified that the following RECD model complies with the provisions of Type Approval of CPCB System Procedure for Retro-fit Emission Control Devices (RECD) Compliance to Diesel Power Generating Set Engines Up to Gross Mechanical Power 800 kW as per NGT Order/report "Report filed in O.A. No. 681/2018 dated 6.08.2019".

| Mechanical Power 800 kW, as per NGT Order/report "Report filed in O.A. No. 681/2018 dated 6.08.2019". |            |  |                     |                           |                    |  |
|---|------------|--|---------------------|---------------------------|--------------------|--|
| Documental Refere   | nce        | RECD Manufacturer  |                     |                           |                    |  |
| Current Certificat  | te 3/1     | M/s Platino Automotive Pvt. Ltd.  3/1, Nadesan Nagar, Ayanambakkam, Chennai, Tamil Nadu, 600095  Plant: Tamil Nadu |                     |                           |                    |  |
| RECD Family Designation Brand Name  |            |  | Engine Manufacturer | Tested Engine Model       |                    |  |
| R3  |            | PLATINO M/s. Cummins India   |                     | s. Cummins India Limited. | KTA-19-G9          |  |
| RECD Model  |            |  |                     | Engine Cubic Capacity     | Gross Engine Power |  |
| C03 NB-HF   |            | 18942 cm <sup>3</sup>  | 448 kW @ 1500 rpm   |                           |                    |  |
| Engine Baseline emissions CPC   | B Stage -I | Class of RECD  | Class II            | Engine Manufacturing Date | Feb 2007           |  |
| C No. Hom Deser   | intina     | Parent RECD Type   |                     |                           |                    |  |
| S. No. Item Description   |            | Annexure-II  |                     |                           |                    |  |
| RECD suitable for Phase I Certified Diesel Generator engine / engine famillies  Annexure-III          |            |  |                     |                           |                    |  |

2. Validity of the Certificate

| This Type Approval Certificate is valid for |
|---|
| Genset engine CPCB Stage -I effective from  |
| 01.07.2004 to 30.06.2014.                   |
|   |

- As per System and procedure for Emission Compliance of Retro-fit Emission Control Devices(RECD) for Diesel Power Generationg Set Engines up to Gross Mechanical power 800kW as per NGT Order/report "Report filed in O.A. No. 681/2018 dated 06.08.2019 or until further amendment in the MoEFCC rule, whichever is earlier.
- b. No change in specified RECD technical specification.

3. It is certified that the above RECD Model (Details listed in Annexure-II)comply with the emission limits for Retro-fit Emission Control Devices (RECD) to Diesel Power Generating Set Engines having Gross Mechanical Power 256.2 kW to 448.0 kW, as prescribed under the following rules, notified by Ministry of Environment, Forest and Climate Change (MoEFCC), Govt. of India:

| Rule No. | Description  | Date       |
|----------|--|------------|
|          | System and procedure for Emission Compliance of Retro-fit Emision Control Devices(RECD) for Diesel Power Generationg Set Engines up to Gross Mechanical power 800kW as per NGT |            |
|          | Order/report "Report filed in O.A. No. 681/2018 dated 6.08.2019  | 0110212022 |

4. COP: COP shall be completed by 30.06.2025 as per CPCB Procedure, for details refer COP Annexure-I.

| AUTHORISED SIGNATORY   |                |           |
|------------------------|----------------|-----------|
|                        |                |           |
|                        |                |           |
|                        |                |           |
|                        |                |           |
|                        |                |           |
|                        |                |           |
| SITARAM KASHYAP        | SAURABH DALELA | Page 1 of |
| DEPUTY GENERAL MANAGER | DIRECTOR       | 6         |