## [National Automotive Board (NAB)]

## C O T G 0248

## Date: 11<sup>th</sup> December 2024

TYPE APPROVAL CERTIFICATE
---------------------------

Date . IT December 2024				
Cert	Report	Specs	Drg	Total
02	05	08	06	21 pgs

COMPLIANCE TO MASS EMISSION & SMOKE NORMS FOR GENSET DIESEL ENGINE (upto 800 kW)

1. In order to establish compliance to the provisions of mass emission & smoke limits, applicable as on date, documental verification / necessary testing was carried out, on following engine model(s), submitted by the engine manufacturer/supplier referred below:

Documental Reference	Engine Manufacturer			
Current Certificate	M/s. Gentek Power 105/2, VPO Bela Bathri, Tehsil Haroli, Dist. Una, Himachal Pradesh - 174301 Plant : Himachal Pradesh			
Engine Family	Engine Supplier (Manufacturer)			
F1	M/s. Gentek Power, 105/2, VPO Bela Bathri, Tehsil Haroli, Dist. Una, Himachal Pradesh - 174301			
Parent E	ngine	Cubic Capacity (cm <sup>3</sup> )	Gross Engine Power	Compliance of Norms w.e.f
GP10	51	1022	7.5 kW @ 1500 rpm	01.07.2023
Variant(s)				

2. Validity of the Certificate

This Type Approval Certificate is valid till	1	The validity of existing emission norms under Notification No. GSR 804(E) dt. 03.11.2022 or until further amendment in the MoEFCC rule, whichever is earlier.
	2	No change in technical specification of the engine specified
	3	Explicitly the Type Approval Certificate withdrawn by the engine supplier
	4	Till COP is not missed / Till COP procedure compliance as per CPCB Administrative Procedure is obtaioned within prescribed time frame.

 It is certified that the above Diesel engine model(s) comply with the emission limits for Genset Engines powered by CI engines under power category (P≤8)kW, as prescribed under the following rules, notified by Ministry of Environment, Forest and Climate Change (MoEFCC), Govt. of India:

Rule No.	Description	Notification	Date
Environment (Protection) Rule, 1986 in the schedule I, Serial number 88	Emission limits for new engines used for power generating set (Genset) application upto 800 kW Gross Mechnical Power	GSR 804 (E)	03.11.2022

4. COP :

COP will be applicable as per CPCB Procedure, for details refer **COP-Annexure**.

Please turn over for Disclaimer

AUTHORISED SIGNATORY		
SITARAM KASHYAP	SAURABH DALELA	Page 1 of
DEPUTY GENERAL MANAGER	DIRECTOR	2