[National Automotive Board (NAB)]

C O U G 0122

TYPE APPROVAL CERTIFICATE Cert Repo

 Date: 17th April 2025

 Cert
 Report
 Specs
 Drg
 Total

 02
 04
 06
 05
 17 pgs

COMPLIANCE TO MASS EMISSION NORMS FOR GASOLINE FUEL RUN PORTABLE GENERATOR SETS

1. In order to establish compliance to the provisions of mass emission limits, applicable as on date, documental verification / necessary testing was carried out, on the following Portable generator set engine model(s), submitted by the engine manufacturer/supplier referred below:

Portable Generator Set Supplier	Portable Engine Assembler/Importer						
M/s NPG Power Equipment LLP	M/s NPG Power Equipment LLP						
Addrs: A-264 1st Floor, Okhla	Engine imported from M/s Sing Seng Global, Unit F, 8th Floor, Far East Mansion, 5-6 Middle Road,						
Industrial Area, Phase-I, New	TST, Kowloon, Hong Kong and imported by M/s NPG Power Equipment LLP, New Delhi						
Delhi-110020	Plant : New Delhi						
Engine Family	Portable G	ortable Generator Set Manufacturer Plant Import Category			ory		
F2	M/s Sing Seng Global, Unit F, 8th		n Floor, Far East	M/s NPG Power Equipment LLP. A-264 1st Fl		A-264 1st Floor,	
12	Mansion, 5-6 Middle Road, TST,		Kowloon, Hong Kong	Okhla Industrial Area, Phase-I, New Delhi		ew Delhi	
Generator Set Engine Model		Displacement (cm ³)	226[]		Compliance of Norms w.e.f	
SW 6500 (engine 5.0 kW Single Cylinder)		420		Class 3		01.07.2023	
Generator Set Model(s) / Br) / Brand Name		Туре		Variant(s)	NIL	
SW 6500 / SWIFT	·	Petrol S	Petrol Start, Petrol Run		MIL		

2. Validity of the Certificate

This Type Approval Certificate is valid till	1	The validity of existing emission norms under Notification No. GSR 804(E) dt. 03.11.2022 or until further amendment in the MoEFCC rule, whichever is earlier.
	2	No change in technical specification of the engine specified
	3	Explicitly the Type Approval Certificate withdrawn by the engine supplier
	4	Till COP is not missed / Till COP procedure compliance as per CPCB Administrative Procedure is obtained within prescribed time frame.

3. It is certified that the above mentioned engine model(s) comply with the emission limits for Genset Engines powered by SI engines under Engine Displacement (cc) category (>225 and upto 800), as prescribed under the following rules, notified by Ministry of Environment, Forest and Climate Change (MoEFCC), Govt. of India:

Rule No.	Description	Notification	Date
Environment (Protection) Rule, 1986 in the schedule I, Serial number 88	Emission limits for new engines used for power generating set (Genset) application upto 19 kW Gross Mechnical Power	GSR 804 (E)	03.11.2022

4. **COP**: COP will be applicable as per CPCB Procedure, for details refer COP-Annexure.

Please turn over for Disclaimer

AUTHORISED SIGNATORY		
SITARAM KASHYAP	SAURABH DALELA	Page 1 of
DEPUTY GENERAL MANAGER	DIRECTOR	2