

TAC/Reference No.

C	T	0	N	T	0	1	4	0
---	---	---	---	---	---	---	---	---

Date : 14th Oct., 2024**ANNEXURE-I**

Air Intake system	Air Filter Make	M/s. HIMALAYAN POWER MACHINE MFG. CO.		
	Type of Air Filter	Dry Type		
Ventilation Fan Details	Fan Dimention, mm	100		
	Speed, rpm	3000		
	kW	0.05		
	Make	M/s. HIMALAYAN POWER MACHINE MFG. CO.		
Silencer Details	External Diameter, mm	32		
	Length, mm	243		
	Height Above Canopy, mm	NA (Tail pipe not use)		
	Max. Back Pressure, kPa	3		
Mounting Arrangement		Insulator mounting HPM		
Acoustic Enclosure Details	Acoustic Material certificate no.	NVH/3223/2011-12/27 (10) Dt. 13th September 2011		
	Outer Dimensions, mm	808(L)x503(B)x601± 5(H)		
	Wall Thickness, mm	1.60		
	Insulation Material Type	PU		
	Insulation Thickness, mm	50 mm		
	Density of Insulation, kg/m³	32 Kg/m ³		
Observed Noise Level at 75% load, LWA		85.87 dB(A)		
<p>Note: Acceptance Limit as per CPCB System & procedure for compliance with noise limits for Petrol Generator set at 1 m is 86 dB(A) Above mentioned PG set models complies with the prescribed noise limit of 86dB(A) at 1 meter from enclosure surface as per Part I of "System Procedure for compliance with Noise Limits for Petrol Generator Sets (up to 1000 kVA)"</p>				
<p>This certificate is valid upto 31st August 2025. After this date the validity of this certificate shall be extended by the Certificate of Conformity of Production verification.</p>				
 				
Place of Issue	Manesar	Test Report No.	CT0NT0139 Dt.10-10-2024	
AUTHORISED SIGNATORY				
IKSHIT SHRIVASTAVA Manager		RAKESH KUMAR Asst. General Manager		SAURABH DALELA
				Director
				Page 2 of 2