

TAC/Reference No.

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| C | T | 0 | N | T | 0 | 1 | 5 | 5 |
|---|---|---|---|---|---|---|---|---|

Date : 21st Oct, 2024

CERTIFICATE

FOR
TYPE APPROVAL FOR NOISE OF DIESEL GENSET

| Cert | Report | Total |
|------|--------|--------|
| 2 | 10 | 12 pgs |

Non- Transferable

| | | | | | |
|----|--|--|-------------------|-----------------|-------------|
| 1 | Name of Customer | M/s. Mass Generators Pvt. Ltd. | | | |
| 2 | Address of Customer | SIDCO Industrial Complex, Old Railway Station Road, Kathua Jammu & Kashmir – Pin Code-184001 | | | |
| 3 | Manufacturer Name | Same as above | | | |
| 4 | Manufacturer Address | Same as above | | | |
| 5 | Generator Set Models | Base | Variant | | |
| | | MAAS/15/SP/TP | MAAS/12.5/SP/TP | | |
| 6 | Genset kVA Rating | 15 | 12.5 | | |
| 7 | Engine TA/COP reference no. & Date | CCTG0176 Dated 23 th August 2024 | | | |
| 8 | Engine Make & Models | EICHER ENGINES & 220A-EG015 | | | |
| 9 | Engine Rating (kW) | 17.6 | | | |
| 10 | Engine Sr. No. | 534524071926 | | | |
| 11 | Type of Engine | 4-Stroke, 2 Cylinder, Air Cooled | | | |
| 12 | Type of Fuel | Diesel | | | |
| 13 | No. of Cylinders | 2 | | | |
| 14 | Rated speed, rpm | 1500 | | | |
| 15 | Cooling Mechanism | Air Cooled | | | |
| 16 | Method of Aspiration | Natural | | | |
| 17 | Details of Quality Management System (QMS) | Type of QMS | Certifying Agency | Certificate No. | Valid Up to |
| | | CPCB Guidelines | ICAT | CT0NT0155 | 12/31/2025 |
| 18 | Approval | √ | | | |
| | | Granted/ Not Granted/ Extended | | | |

Based on the verification of the documents and tests conducted on the genset models MAAS/15/SP/TP manufactured by M/s. Mass Generators Pvt. Ltd. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph1&3) of schedule I of the Environment (Protection) Rules, 1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference

| |
|--------------------|
| CETNMASTLNVH180620 |
|--------------------|

 Please turn over for DISCLAIMER**AUTHORISED SIGNATORY**

| | | | |
|--------------------------------------|--|-----------------------------------|----------------|
| | | | |
| IKSHIT SHRIVASTAVA Manager | RAKESH KUMAR Asst. General Manager | SAURABH DALELA Director | Page 1 of 2 |