

TAC/Reference No.

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| C | T | 0 | N | T | 0 | 1 | 5 | 7 |
|---|---|---|---|---|---|---|---|---|

Date : 21st Oct, 2024

CERTIFICATE

FOR
TYPE APPROVAL FOR NOISE OF DIESEL GENSET

| Cert | Report | Total |
|------|--------|--------|
| 2 | 10 | 12 pgs |

Non- Transferable

| | | | | | |
|---------------------------------------|--|--|-------------------|-----------------|-------------|
| 1 | Name of Customer | M/s. Mass Generators Pvt. Ltd. | | | |
| 2 | Address of Customer | SIDCO Industrial Complex, Old Railway Station Road, Kathua Jammu & Kashmir – Pin Code-184001 | | | |
| 3 | Manufacturer Name | Same as above | | | |
| 4 | Manufacturer Address | Same as above | | | |
| 5 | Generator Set Models | Base | Variant | | |
| | | MAAS/40/SP/TP | MAAS-30-W/SP/TP | | |
| 6 | Genset kVA Rating | 40 | 30 | | |
| 7 | Engine TA/COP reference no. & Date | CCTG0203 Dated 25 th September 2024 | | | |
| 8 | Engine Make & Models | TAFE MOTORS AND TRACTORS LIMITED and 333W0-EG040 | | | |
| 9 | Engine Rating (kW) | 39.6 | | | |
| 10 | Engine Sr. No. | 534522796648 | | | |
| 11 | Type of Engine | 4-Stroke, 3 Cylinder, Liquid Cooled | | | |
| 12 | Type of Fuel | Diesel | | | |
| 13 | No. of Cylinders | 3 | | | |
| 14 | Rated speed, rpm | 1500 | | | |
| 15 | Cooling Mechanism | Liquid Cooled | | | |
| 16 | Method of Aspiration | Turbocharge and Intercooler | | | |
| 17 | Details of Quality Management System (QMS) | Type of QMS | Certifying Agency | Certificate No. | Valid Up to |
| | | CPCB Guidelines | ICAT | CTONT0157 | 12/31/2025 |
| 18 | Approval | √ | | | |
| Granted/ Not Granted/ Extended | | | | | |

Based on the verification of the documents and tests conducted on the genset models MAAS/40/SP/TP manufactured by M/s. Mass Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph 1&3) of schedule I of the Environment (Protection) Rules, 1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference: CETNMASTLNH180621 Please turn over for DISCLAIMER

AUTHORISED SIGNATORY

| | | | |
|-------------------------------|---------------------------------------|----------------------------|----------------|
| | | | |
| IKSHIT SHRIVASTAVA Manager | RAKESH KUMAR Asst. General Manager | SAURABH DALELA Director | Page 1 of 2 |