

TAC/Reference No.

C	T	0	N	T	0	1	5	5
---	---	---	---	---	---	---	---	---

Date : Date : 21st Oct, 2024

CERTIFICATE

FOR
TYPE APPROVAL FOR NOISE OF DIESEL GENSET

Cert	Report	Total
2	10	12 pgs

Non- Transferable

1	Name of Customer	M/s. Mass Generators Pvt. Ltd.			
2	Address of Customer	SIDCO Industrial Complex, Old Railway Station Road ,Kathua Jammu & Kashmir – Pin Code-184001			
3	Manufacturer Name	Same as above			
4	Manufacturer Address	Same as above			
5	Generator Set Models	Base	Variant		
		MAAS/15/SP/TP	MAAS/12.5/SP/TP		
6	Genset kVA Rating	15	12.5		
7	Engine TA/COP reference no. & Date	CCTG0176 Dated 23 th August 2024			
8	Engine Make & Models	EICHER ENGINES & 220A-EG015			
9	Engine Rating (kW)	17.6			
10	Engine Sr. No.	534524071926			
11	Type of Engine	4-Stroke, 2 Cylinder, Air Cooled			
12	Type of Fuel	Diesel			
13	No. of Cylinders	2			
14	Rated speed, rpm	1500			
15	Cooling Mechanism	Air Cooled			
16	Method of Aspiration	Natural			
17	Details of Quality Management System (QMS)	Type of QMS	Certifying Agency	Certificate No.	Valid Up to
		CPCB Guidelines	ICAT	CTONT0155	12/31/2025
18	Approval	√			
		Granted/ Not Granted/ Extended			

Based on the verification of the documents and tests conducted on the genset models MAAS/15/SP/TP manufactured by M/s. Mass Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph1&3) of schedule I of the Environment (Protection) Rules,1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference	CETNMASTLNVH180620	Please turn over for DISCLAIMER
----------------	--------------------	---------------------------------

AUTHORISED SIGNATORY

IKSHIT SHRIVASTAVA Manager	RAKESH KUMAR Asst. General Manager	SAURABH DALELA Director	Page 1 of 2