

TAC/Reference No. C T 0 N U 0 0 4 1

Date : 18thFebuary 2025

CERTIFICATE

Cert	Report	Total
2	11	13 pgs

FOR

TYPE APPROVAL FOR NOISE OF DIESEL GENSET

Non- Transferable

1	Name of Customer	M/s. MAAS Generators Pvt. Ltd.			
2	Address of Customer	SIDCO Industrial Complex,Old Railway Station Road ,Kathua Jammu & Kashmir – Pin Code-184001			
3	Manufacturer Name	Same as above			
4	Manufacturer Address	Same as above			
5	Generator Set Models	Base		Variant	
		MAAS/25/SP/TP		MAAS/20/SP/TP	
6	Genset kVA Rating	25		20	
7	Engine TA/COP reference no. & Date	CCTG0177 Dated 23 th August 2024			
8	Engine Make & Models	TAFE MOTORS AND TRACTORS LIMITED and 329A0-EG025			
9	Engine Rating (kW)	25.5			
10	Engine Sr. No.	534725834524			
11	Type of Engine	4-Stroke, 3 Cylinder, Air Cooled			
12	Type of Fuel	Diesel			
13	No. of Cylinders	3			
14	Rated speed, rpm	1500			
15	Cooling Mechanism	Air Cooled			
16	Method of Aspiration	Turbocharger and Intercooler			
17	Details of Quality Management System (QMS)	Type of QMS	Certifying Agency	Certificate No.	Valid Up to
		CPCB Guidelines	ICAT	CT0NU0041	12/31/2025
18	Approval	√			
		Granted/ Not-Granted/ Extended			

Based on the verification of the documents and tests conducted on the genset model MAAS/25/SP/TP manufactured by M/s.MAAS Generators Pvt. Ltd., it is certified that the above plants producing of generator set families and models mentioned above, comply with the provisions of Govt. of India notification G.S.R.371 (E), dated 17th May, 2002 and its amendments till date at serial no.94 (paragraph1&3) of schedule I of the Environment (Protection) Rules,1986. (Noise limit for diesel generator sets upto 800 kW).

ICAT Reference CETNMASSUANVH182841 Please turn over for DISCLAIMER

AUTHORISED SIGNATORY				Page 1 of 2
ANJANA KUMARI Sr.Engineer	IKSHIT SHRIVASTAVA Manager		SAURABH DALELA Director	